

Marysville Division of Fire (OH)
209 South Main St
Marysville, OH 43040

Fire Dept Violation Notice

August 11, 2017

St. Johns Lutheran Church
12809 State Route 736
Marysville, OH 43040

An inspection of your facility on Aug 11, 2017 revealed the violations listed below.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on Sep 10, 2017.

If you fail to comply with this notice before the reinspection date listed, you may be liable for the penalties provided for by law for such violations.

Violations

1011.2 Illumination

Note Exit sign not illuminated



Inspection Note Fire Extinguishers
VFP 11/17
SA graves 54-25-1931

Alarm System
Habitec 2017
54-25-4184



28-97 Chad Jolliff
Inspector



Chris Ingram